

## LAKE PLACID VILLAGE ELECTRIC

### RULES FOR SERVICE

All meter locations will be approved by the Electric department.  
Prior to hook up, the Service Request will be signed by the following:

- A. The Village Office
- B. The Building Inspector
- C. The Electrical Inspector

## **ALL SERVICES IN THE LAKE PLACID SERVICE AREA ARE REQUIRED TO HAVE DISCONNECTS**

### OVERHEAD SERVICES

1. All services will have a riser pipe through the roof.
2. The riser pipe will be 2" galvanized minimum.
3. Pipe will be at least 18" above the roof.
4. Any pipe over 36" above the roof will be back guyed.
5. Meter sockets and mast insulators will be supplied by the contractor.

### UNDERGROUND SERVICES

1. All underground will be in conduit.
2. Conduit under roads and driveways will be schedule 80.
3. Primary cable will be 4 ft. deep. Secondaries will be 2 ft. deep.
4. Marking tape will be installed 1 ft. below final grade.
5. Ditches will be inspected by the Village prior to backfilling.
6. Contractor will install first 10 ft. on pole and it will be schedule 80.
7. Pipe, straps and weather head will be supplied by the contractor.
8. Meter sockets will be mounted on pressure treated 6 X 6.
9. Meter height will be 4 ft. to the center of the meter.
10. Services in Lake Placid will have disconnects.
11. Vaults are required for pad mount transformers.
12. Vaults will be installed 8" above grade with 1 ft. crusher run for base.
13. Two ground rods will be installed at opposite corners with ground wire looped between them with 6 ft. tails above the vault.
14. Terminations (load break elbows and lugs) will be supplied by the contractor.
15. Bollards (concrete filled 4" rigid) may be required to protect pad mount transformers.

LAKE PLACID VILLAGE MUNICIPAL ELECTRIC SERVICE REQUEST  
LPV Electric Dept: 518-523-2021, TNE Code Enforcement: 518-523-9518  
LPV Billing Office: 518-523-2597

Customer Name: \_\_\_\_\_

Service Address: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

911 Address: \_\_\_\_\_

Contractor: \_\_\_\_\_

Electrician: \_\_\_\_\_

Type of Service:  Residential  Commercial  Other: \_\_\_\_\_

Type of Use:  Residential Primary  Garage  Apartment  Commercial  
 Other: \_\_\_\_\_

Service Size: AMPS \_\_\_\_\_ Voltage \_\_\_\_\_ Phase \_\_\_\_\_

The following signatures are required, in the order listed, before service performed.

LPV Electric Site Inspection: \_\_\_\_\_

Town of North Elba Code Enforcement Officer: \_\_\_\_\_

Electrical Inspector: \_\_\_\_\_

Electric Billing Office: \_\_\_\_\_ New Acct #: \_\_\_\_\_

A TP-385 Sales Tax Exempt form is required for all residential accounts.

Description of Work to Be Done: \_\_\_\_\_

**NOTES:**

- All overhead services will have a mast through the roof.
- All underground primaries and secondaries in conduit.
- Ditches will be inspected prior to backfilling.
- The customer will provide the meter socket.
- The meter will be spotted by the Village prior to installation.
- An easement is required prior to crossing another's property.
- No electric boilers permitted.
- Electric is not allowed in the same ditch with water or sewer utilities.